



Food Program Official Inspection Report

Siskiyou County Community Development Department
 Environmental Health Division
 806 S. Main Street
 Yreka, California 96097
 phone: (530) 841-2100, fax: (530) 841-4076

Facility Name: Lake Siskiyou Store		Permit # 100171
Address: 4239 W.A Barr Rd., Mount Shasta, CA,		
Permit Holder: Reynolds Resorts		Permit To Operate: <input type="checkbox"/> Valid <input type="checkbox"/> Not Valid
Phone: 530-926-1865		E-mail: acastillo@highwaywest.com
Food Safety Certified Employee:		Expiration Date:

		MAJ	OUT	COS	The marked items represent Health Code violations and must be corrected as follows:
Protection Time/ Temp.	1 Food Temp.		X		<p style="text-align: center;">ROUTINE INSPECTION CONDUCTED THIS DATE</p> <p>36) This facility is currently under ownership change. The current permit is non-transferable and the new owners will need to obtain a permit from this department prior to operating. Failure to obtain a new permit will result in a fine for each day of operation without a valid permit.</p> <p>1) Observed cold food stored in the display refrigerator held @ 48 degrees F. Hold all cold food @ 41 degrees F or colder. Ensure that the stored food does not block the cooling vents. Corrected during inspection.</p> <p>3) Observed raw eggs held in the display refrigerator stored over ready to eat foods. Ensure all raw foods are stored below ready to eat foods and never above or next to them. Correct immediately.</p> <p>3) Observed cases of butter and other foods stored on floor of the walk-in refrigerator. Store all food at least 6" above the ground. Pressurized beverages may be stored directly on the floor. Correct asap.</p> <p>20) The previous food manager certificate holder is no longer employed at this facility. Obtain a new food manager certificate within 60 days.</p> <p>20) All employees that handle food or wares are required to obtain a food handler card within 30 days of hire. Ensure these are all available for inspection at all times.</p> <p>29) Observed excessive debris and buildup under equipment and in hard to reach places. Maintain floors and all equipment in a cleanly manner. Correct asap.</p> <p>IN THE ICE MACHINE ROOM....</p> <p>28) There are large gaps around the door. These gaps need to be corrected to prevent access to vermin, dust, and other contaminants.</p> <p>30) Observed the FRP broken, missing, warped, and unserviceable on all walls and ceilings of this room. Since food prep is performed in this area, the floors, walls, and ceilings are required to be smooth, durable, easily cleanable, and non-absorbent. Correct asap.</p>
	2 Prep./ Service				
	3 Storage/ Disp.		X		
	4 Frozen Food				
	5 Pure Food				
	6 Reused Food				
	7 Transportation				
Food Storage	8 Storage Fac.				
	9 Refrig. Units				
	10 Thermometer				
	11 Hazardous Mat.				
	12 Spoils				
Uten./Equip.	13 Wash/ Sanitize				
	14 Equip. Condition				
	15 Utensil Condition				
Employee	16 Storage				
	17 Handwashing				
	18 Employee Hygiene				
	19 Employee Habits				
Water	20 Food Cert./ Card		X		
	21 Water				
Waste	22 Cross Con.				
	23 Liquid Waste				
Vermin	24 Refuse				
	25 Rodents/ Insects				
Facilities	26 Animal/ Fowl				
	27 Ventilation				
	28 Doors		X		
	29 Floors		X		
	30 Walls - Ceilings		X		
	31 Toilet Fac.				
	32 Janitorial Fac.				
Misc.	33 Lighting				
	34 Clothing - Linen				
	35 Signs				
	36 Misc.		X		

MAJ = Major violation OUT = Out of compliance COS = Corrected on-site	
Received By (Print): Adin Castillo	Received by (Signature): _____ Date: 07/31/2025
REHS (Print): Rick Florendo	REHS (Signature): _____ Phone: 530-841-2114

Facility Name: Lake Siskiyou Store

The marked items represent Health Code violations and must be corrected as follows:

Received By (Print): Adin Castillo	Received by (Signature):	Date: 07/31/2025
---------------------------------------	--------------------------	---------------------

REHS (Print): Rick Florendo	REHS (Signature):	Phone: 530-841-2114
--------------------------------	-------------------	------------------------

Facility Name: Lake Siskiyou Store

The marked items represent Health Code violations and must be corrected as follows:

Received By (Print): Adin Castillo	Received by (Signature):	Date: 07/31/2025
---------------------------------------	--------------------------	---------------------

REHS (Print): Rick Florendo	REHS (Signature):	Phone: 530-841-2114
--------------------------------	-------------------	------------------------

Facility Name: Lake Siskiyou Store

The marked items represent Health Code violations and must be corrected as follows:

Received By (Print): Adin Castillo	Received by (Signature):	Date: 07/31/2025
---------------------------------------	--------------------------	---------------------

REHS (Print): Rick Florendo	REHS (Signature):	Phone: 530-841-2114
--------------------------------	-------------------	------------------------