



RFP #RG1225

Q & A Document

Q: Is there a set date for the job walk?

A: No, there is no set date. The RFP states that a walk-through is to be scheduled with the appropriate contact, shown on page 4, and conducted prior to the deadline, shown on page 2.

Q: Is the address 1457 White Rock Rd., Grenada, CA 96038, correct?

A: Yes, that is the job site location.

Q: Is this a prevailing wage project?

A: Yes, Section 14(c) of our Public Works Contract for capital improvements, requires us as government entity to pay prevailing wage, specific to skilled labor.

Q: Do you want base rock imported and compacted under the concrete area, or pour on top of existing ground?

A: I suggest a walk-through for this question and make the best determination based on your knowledge and experience. If existing grounds are deemed suitable, and additional materials are not needed, we always strive for the best utilization of funds.

Q: What PSI concrete is required?

A: It's my understanding 2,500-3,000 PSI is desired, but we welcome and appreciate any vendor insight. You can quote multiple PSI options for the committee to weigh.

Q: Does the concrete need to have rebar or reinforcing fiber?

A: Yes, we desire rebar or similar reinforcement.

Q: Can the insurance limits stated in the County's Public Works Contract be negotiated or will the County consider other limits?



RFP #RG1225

A: The County's Public Works Contract is standard for all projects of capital improvement, but you can submit a different ceiling per policy for Risk Management to review. If you wish to do so in your bid, please specify the type of insurance policy you are referencing, the new limit requested, and a comment or justification for support.
